



February 28, 2024

The Corporation of the Municipality of Huron East  
72 Main St. S  
P.O. Box 610  
Seaforth, ON  
N0K 1W0

**Attention: Brad McRoberts, CAO**

**RE: Vanastra Booster System  
2023 Annual Report**

Dear Brad,

Please find attached the 2023 Annual Operations Report for the Vanastra Water System, in accordance with Section 11(1) of O. Reg. 170/03. This report covers the period from January 1 to December 31 and meets the requirement of being prepared by February 29 of this year.

Please ensure that a copy of this report is given, without charge, to every person who requests a copy. In addition, please make certain that effective steps are taken to advise residents that copies of the report are available, and of how a copy can be obtained.

As per Schedule 22 of O. Reg. 170/03, please ensure that at least a copy of the Summary Report is given to the members of municipal council no later than March 31, 2024.

Finally, please ensure that a letter is sent to Jacobs verifying that this report has been received and accepted by Council.

If you have any questions regarding the report, we would be pleased to address them and you should contact the undersigned accordingly.

Sincerely,

Jacobs (OMI Canada Inc.)

A handwritten signature in black ink, appearing to read "A. Yungblut", with a long horizontal stroke extending to the right.

Aaron Yungblut

Project Manager/Overall Responsible Operator (ORO)  
Huron East Project  
226 921 5420

cc. B. Mills, Municipality of Huron East;

## 2023 ANNUAL REPORT FOR WATER SYSTEMS

### Part 1 – ANNUAL REPORT (as required by O. Reg. 170/03, Section 11)

<b>Drinking-Water System Number:</b>	210001585
<b>Drinking-Water System Name:</b>	Vanastra Water Works
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of Huron East
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1-December 31, 2023

Complete if your Category is Large Municipal Residential or Small Municipal Residential	Complete for all other Categories
Does your Drinking-Water System serve more than 10,000 people? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Number of Designated Facilities served: N/A
Is your annual report available to the public at no charge on a web site on the Internet? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Did you provide a copy of your annual report to all Designated Facilities you serve? <input type="checkbox"/> Yes <input type="checkbox"/> No
Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection. <b>Town Office</b> <b>72 Main St. S.</b> <b>Seaforth, ON</b>	Number of Designated Facilities served: N/A Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? <input type="checkbox"/> Yes <input type="checkbox"/> No

**List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
N/A	

**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?**

**Indicate how you notified system users that your annual report is available, and is free of charge.**

<input checked="" type="checkbox"/> Public access/notice via the web	<input checked="" type="checkbox"/> Public access/notice via Government Office	<input type="checkbox"/> Public access/notice via a newspaper
<input type="checkbox"/> Public access/notice via Public Request	<input type="checkbox"/> Public access/notice via a Public Library	<input type="checkbox"/> Public access/notice via other method

**Water Distribution System Class 2 Including 1 Underground Reservoir and Booster Station**

The underground single cell reservoir is located at #12,5<sup>th</sup> Ave, Vanastra. It has a capacity of 1135 m<sup>3</sup>. 3 electric distribution high lift pumps are located on this site. Pumps #1 & #2 are rated at 11.6 L/s at 48.8 m TDH and pump #3 is rated at 105L/s at 25 m TDH. There are two sodium hypochlorite pumps that are able increase the incoming chlorine when needed. This pumphouse is equipped with a 125 kW generator with an automatic transfer switch for backup power. The village of Vanastra receives treated drinking water from the Municipality of Central Huron.

List all water treatment chemicals used over this reporting period
12% Sodium hypochlorite solution

Please provide a brief description and a breakdown of monetary expenses incurred
N/A

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre					
Incident Date	Parameter	Result	Units	Corrective Action	Corrective Action Date
N/A					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period					
	Number of Samples	Range of E.Coli Results (min #) - (max #)	Range of Total Coliform Results (min #) - (max #)	Number of HPC Samples	Range of HPC Results (min #) - (max #)
Raw	N/A	N/A	N/A	N/A	N/A
Treated	52	0	0	52	<10 - 60
Distribution	104	0	0	52	<10 - >2000

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report			
	Number of Grab Samples	Range of Results (min #) – (max #)	Units
Turbidity	N/A	N/A	NTU
Chlorine	8760	0.61-4.12	mg/L
Fluoride (If the DWS provides fluoridation)	N/A		

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument				
Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
None				

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results. Note: Inorganic parameters are sampled by the Municipality of Central Huron.**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	N/A			
Arsenic	N/A			
Barium	N/A			
Boron	N/A			
Cadmium	N/A			
Chromium	N/A			
Haloacetic Acids (HAA's). <i>Running Annual Average</i>	Q1 – Q4 2023	<5.3	ug/L	No
Lead-sampling conducted by the Municipality of Huron East; see summary below				
Mercury	N/A			
Selenium	N/A			
Sodium	N/A			
Uranium	N/A			
Fluoride	N/A			
Nitrite	N/A			
Nitrate	N/A			
Nitrite	N/A			
Nitrate	N/A			
Nitrite	N/A			
Nitrate	N/A			
Nitrite	N/A			
Nitrate	N/A			

**Summary of Lead Results\***

Sampling Period	Range of Results (µg/L)	Non-residential	Distribution	Adverse Incidents?
Dec-15-22-Apr-15-23	0.13-0.28	N/A	2	No
Jun-15-23-Oct-15-23	0.23-1.98	N/A	2	No

**Summary of Organic parameters tested during this reporting period or the most recent sample results. Note: Organic parameters are sampled by the Municipality of Central Huron.**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	N/A			
Atrazine	N/A			
Atrazine + N-dealkylated metabolites	N/A			
Azinphos-methyl	N/A			
Benzene	N/A			
Benzo(a)pyrene	N/A			
Bromoxynil	N/A			
Carbaryl	N/A			
Carbofuran	N/A			
Carbon Tetrachloride	N/A			
Chlorpyrifos	N/A			

Summary of Organic parameters tested during this reporting period or the most recent sample results. Note: Organic parameters are sampled by the Municipality of Central Huron.				
Diazinon	N/A			
Dicamba	N/A			
1,2-Dichlorobenzene	N/A			
1,4-Dichlorobenzene	N/A			
1,2-Dichloroethane	N/A			
1,1-Dichloroethylene (vinylidene chloride)	N/A			
Dichloromethane	N/A			
2,4 Dichlorophenol	N/A			
2,4-Dichlorophenoxy acetic acid (2,4-D)	N/A			
Diclofop-methyl	N/A			
Dimethoate	N/A			
Diquat	N/A			
Diuron	N/A			
Glyphosate	N/A			
Desethyl atrazine	N/A			
Lorpyrifos	N/A			
Malathion	N/A			
Metolachlor	N/A			
MCPA	N/A			
Metribuzin	N/A			
Monochlorobenzene	N/A			
Paraquat	N/A			
Pentachlorophenol	N/A			
Phorate	N/A			
Picloram	N/A			
Polychlorinated Biphenyls(PCBs)	N/A			
Prometryne	N/A			
Simazine	N/A			
THM (NOTE: show latest annual average)	Q1-Q4 2023	15.8	µg/L	No
Terbufos	N/A			
Tetrachloroethylene	N/A			
2,3,4,6-Tetrachlorophenol	N/A			
Triallate	N/A			
Trichloroethylene	N/A			
2,4,6-Trichlorophenol	N/A			
Trifluralin	N/A			
Vinyl Chloride	N/A			

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.				
Parameter	Sample Date	Result Value	Unit of Measure	ODWS Criteria
None				

## Part 2 – SUMMARY REPORT (as required by O. Reg. 170/03, Schedule 22)

### Non – Compliance with Legislations, Regulations, Approvals & Orders

During this period, the Facility was operated in full compliance with the Act, the regulations and the Facility's approval, save and except for the following:

Requirement	Description	Measures to Correct the Failure
N/A (Received a 100% inspection rating in MECP Inspection Report).		

System Capability Assessment		
Monthly Raw Water Taking (m <sup>3</sup> /d):		
Month	Average Flow	Maximum Flow
January	145	213
February	191	211
March	196	216
April	231	870
May	206	228
June	222	241
July	175	202
August	165	197
September	169	212
October	230	757
November	159	205
December	146	196
<b>AVERAGE</b>	<b>186</b>	<b>312</b>
<b>MAXIMUM</b>	<b>231</b>	<b>870</b>
<b>SYSTEM CAPACITY</b>	<b>N/A</b>	<b>N/A</b>
<b>% CAPACITY</b>	<b>N/A</b>	<b>N/A</b>
<b>Total Annual Flow: 67 933 m<sup>3</sup></b>		